

# Copy of the Fire Safety Certificate



## Karnataka Fire and Emergency Services Department

Office of the District fire officer,  
Jnanabharathi fire station

Bangalore University Premissess, Bangalore – 560 056.  
Ph No.080 – 22971614



No.43/FSR/DF0/JBFS/2025.

Date. 16-06-2025.

To,

The Principal  
M/s. JES Public School  
NGEF Layout, Nagarabhavi 1<sup>st</sup> Stage  
1<sup>st</sup> Stage, Bengaluru  
Bengaluru-560072

Sir,

**Sub:** Issue of **Fire Safety Recommendation** with respect of Fire prevention fire fighting and evacuation measures required at **M/s. JES Public School, NGEF Layout, Nagarabhavi 1<sup>st</sup> Stage Bengaluru-560072.**

**Ref:** Your letter dated:-12-06-2025

\*\*\*\*\*

### ANNEXURE-B

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

( These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)

\*\*\*\*\*

With reference to the subject cited above, I have inspected the premises of **M/s. JES Public School, NGEF Layout, Nagarabhavi 1<sup>st</sup> Stage, Bengaluru- 560072** on 13-06-2025 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the premises and the details as under:-

#### A. Details of the building / premises :-


01	Name and Address of the Applicant.	: The Principal M/s. JES Public School, NGEF Layout, Nagarabhavi 1 <sup>st</sup> Stage Bengaluru-560072
----	------------------------------------	--



PRINCIPAL  
**JES PUBLIC SCHOOL**  
CBSE Affiliation No: 830841  
NGEF Layout, (Nrupatunganagara)  
Nagarabhavi 1st Stage, Bengaluru-560072

SECRETARY  
JES PUBLIC SCHOOL  
CA 1, NGEF Layout,  
Nrupatunganagara  
Nagarabhavi 1st Stage  
Bengaluru 560 072

02	Name and Address of the premises.	:	<b>M/s. JES Public School, NGEF Layout, Nagarabhavi 1<sup>st</sup> Stage Bengaluru-560072</b>
03	Name and address of the Building owner	:	<b>M/s. JES Public School, NGEF Layout, Nagarabhavi 1<sup>st</sup> Stage Bengaluru-560072</b>
04	Number of buildings	:	One Building
05	Number of floors	:	Ground & 03 upper floors
06	<b><u>Floor-wise details of occupancy:-</u></b>		
	Ground floor	:	01 Office, 01 Staff room, 01 Director, 05 Class room
	1 <sup>st</sup> floor	:	07 Classroom, 03 Lab,
	2 <sup>nd</sup> floor	:	06 Class rooms, 01 Staff room,
	3 <sup>rd</sup> floor	:	03 Class rooms
07	Height of the buildings:-	:	12.50 mtrs
08	Site area	:	1557.00 Sq mtrs .
09.	<b><u>Built-up area of each floor:-</u></b>		
	Ground floor	:	768.20 Sq.mtrs
	1 <sup>st</sup> floor	:	768.20 Sq.mtrs
	2 <sup>nd</sup> floor	:	768.20 Sq.mtrs
	3 <sup>rd</sup> floor	:	75.75 Sq.mtrs
10.	<b>Total built-up area</b>	:	<b>1850.38 Sq.mtrs.</b>
11.	<b><u>Surrounding properties:-</u></b>		
	North (Front)	:	06.00 mtrs wide 4 <sup>th</sup> Main road NGEF layout main Road
	South (Rear)	:	Vacant Land
	East (Side)	:	Vacant Land
	West (Side)	:	Commercial Building
12.	<b><u>Set-back area available around the building :-</u></b>		
	North (Front)	:	01.00 mtrs
	South (Rear)	:	01.00 mtrs
	East (Side)	:	01.00 mtrs
	West (Side)	:	01.00 mtrs
	<b>Allowed setbacks (Open space) Should be maintained free from further obstruction/construction</b>		

  
 PRINCIPAL  
**JES PUBLIC SCHOOL**  
 CBSE Affiliation No: 830841  
 NGEF Layout, (Nrupatunganagara)  
 Nagarabhavi 1st Stage, Bengaluru-560072

  
 SECRETARY  
**JES PUBLIC SCHOOL**  
 CA 1, NGEF Layout,  
 Nrupatunganagara  
 Nagarabhavi 1st Stage  
 Bengaluru 560 072





**B. On inspection of this School/Collage premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-**

Sl. No.(1)	Details (02 )	Existing (03 )	Recommendations (04 )																					
1.	Accessibility to the premises	The premise is accessible from 06.00 mtrs wide 4 <sup>th</sup> Main road NGEF layout main Road located on Nothern side The road is hardened to carry the Weight of 45,000 Kgs	Adequate.																					
2.	No. of entrances	01 Entrances with entry & Exit.	Adequate.																					
3.	Width of entry / exit	03.00 mtrs width on eastern side have been provided.	Adequate.																					
4.	Number of staircases Available	<table><tr><td>Nos. of staircases</td><td>:</td><td>01</td></tr><tr><td>Width of staircases</td><td>:</td><td>0.90 mtrs</td></tr><tr><td>Width of treads</td><td>:</td><td>30 Cm</td></tr><tr><td>Height of risers</td><td>:</td><td>15 Cm.</td></tr><tr><td>Nos. of riser per flight</td><td>:</td><td>10/9 No's</td></tr><tr><td>Height of handrails</td><td>:</td><td>09.00 mtrs</td></tr><tr><td>Head room clearance</td><td>:</td><td>03.00Mtrs</td></tr></table>	Nos. of staircases	:	01	Width of staircases	:	0.90 mtrs	Width of treads	:	30 Cm	Height of risers	:	15 Cm.	Nos. of riser per flight	:	10/9 No's	Height of handrails	:	09.00 mtrs	Head room clearance	:	03.00Mtrs	Complied
Nos. of staircases	:	01																						
Width of staircases	:	0.90 mtrs																						
Width of treads	:	30 Cm																						
Height of risers	:	15 Cm.																						
Nos. of riser per flight	:	10/9 No's																						
Height of handrails	:	09.00 mtrs																						
Head room clearance	:	03.00Mtrs																						
5.	Portable Fire extinguisher	15 No's of ABC fire Extinguisher of 04 Kgs Capacity, and 02 no's of Co <sub>2</sub> fire Extinguisher of 2.5 Kgs Capacity each floor of every building have been provided.	Complied																					



PRINCIPAL  
**JES PUBLIC SCHOOL**  
 CBSE Affiliation No: 830841  
 NGEF Layout, (Nrupatunganagara)  
 Nagarabhavi 1st Stage, Bengaluru-560072



SECRETARY  
**JES PUBLIC SCHOOL**  
 CA 1, NGEF Layout,  
 Nrupatunganagara  
 Nagarabhavi 1st Stage  
 Bengaluru 560 072



6.	First aid Hose reel hose.	Hose Reel Hose system have been provided near the staircases. Each hose reel hose of min 19mm size and of adequate length to reach the farthest point of each floor have been provided shut off branch having a nozzle of 5mm size. The hose reel hose have been connected at each landing.	Complied
7.	Terrace Pump at the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup> .	Each Hose real hose system have been connected to an Booster pump capable of delivering 450 LPM (Further the system should be connected to an alternative source of power supply)	Complied
8.	Terrace tank over respective tower terrace.	Each Hose real hose system Have been connected to an over head tank of 10,000 ltrs capacity. (The water tank should be kept exclusively for firefighting).	Complied
9.	Public address system	Public address system with 2 way communication facility near the staircase landing with its console at the control room, located on the ground floor of Building have be provided.	Complied
10.	Escape routes	Escape routes and fire exits boards have been displayed at corridors or passages and appropriate places of the building to guide the students and staff to safer places during emergency or fire.	Displayed.



PRINCIPAL  
**JES PUBLIC SCHOOL**  
 CBSE Affiliation No: 830841  
 NGEF Layout, (Nrupatunganagara)  
 Nagarabhavi 1st Stage, Bengaluru-560072



SECRETARY  
**JES PUBLIC SCHOOL**  
 CA 1, NGEF Layout,  
 Nrupatunganagara  
 Nagarabhavi 1st Stage  
 Bengaluru 560 072





11.	Fire order (fire safety Plans)	A notice board indicating the details of actions to be taken in case of emergency have been displayed near each staircase landings with the telephone numbers of our Jnanabharathi Fire Station 080-22971614 or 101 or 112, and telephone numbers of nearest Ambulance Service.	Complied
12.	No Smoking board	COTPA Sec-4 direction No smoking area, Smoking is an offence board have been written in English and kannada both language shall be prominently displayed at inside the entry/exit of each floor.	Complied
13.	Fire siren	A fire siren has been installed in the premises to inform the inmates in the case of a fire emergency and evacuate the area.	Complied
14.	Fire fighting training	Not yet Trained	At least 40% of Teaching and non teaching staff should be got trained basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore.

**Fire precautionary measures :-**

- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction.
- D. Liquefied petroleum gas should not be stored in the building.
- E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to



PRINCIPAL  
**JES PUBLIC SCHOOL**  
CBSE Affiliation No: 830841  
NGEF Layout, (Nrupatunganagara)  
Nagarabhavi 1st Stage, Bengaluru-560072



SECRETARY  
**JES PUBLIC SCHOOL**  
CA 1, NGEF Layout,  
Nrupatunganagara  
Nagarabhavi 1st Stage  
Bengaluru 560 072




outside.


G.As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14<sup>th</sup> of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Service Department is Issue of 'Fire Safety Recommendation' to M/s. **JES Public School, NGEF Layout, Nagarabhavi 1<sup>st</sup> Stage, Bengaluru- 560072** subject to condition and compliance of the above recommendations in column-4 of serial-B within 3 months and compliance to the undersigned.

Yours faithfully.

  
District Fire Officer  
Jnanabharathi Fire Station  
Bengaluru - 560 056

  
PRINCIPAL  
**JES PUBLIC SCHOOL**  
CBSE Affiliation No: 830841  
NGEF Layout, (Nrupatunganagara)  
Nagarabhavi 1st Stage, Bengaluru-560072

  
SECRETARY  
JES PUBLIC SCHOOL  
CA 1, NGEF Layout,  
Nrupatunganagara  
Nagarabhavi 1st Stage  
Bengaluru 560 072